LISTING SERVICE

LISTING No.　　　　7300-0026:252　　　　　　　　　　　　　　　　　Page 1 of 1

CATEGORY:　　　　Misc. Devices/Control Unit Accessories

LISTEE:　　　　Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
　　　　　　　　Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN:　　　　Models 4090-9116, *-9116TSP, *-9116TTP IDNet Isolator; 4090-9117 power Isolator; and
　　　　　　　　4090-9121 security IAM. Refer to listee's data sheet for additional detailed product
　　　　　　　　description and operational considerations.

RATING:　　　　24 VDC

INSTALLATION:　　　　In accordance with listee's printed installation instructions, applicable codes and ordinances,
　　　　　　　　and in a manner acceptable to the authority having jurisdiction.

MARKING:　　　　Listee's name, model number, electrical rating, and UL label.

APPROVAL:　　　　Listed as control unit accessories for use with listee's separately listed compatible fire alarm
　　　　　　　　control units. Refer to listee's Installation Instruction Manual for details.

*Rev. 09-25-03

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:　　　　**JUNE 17, 2004**　　　　　　*Listing Expires **June 30, 2005***

A*uthorized By:*　　　　**DIANE K. AREND**, *Senior Deputy*
　　　　　　　　Program Manager